

# IDNext 902 P -HC

Electronic controllers compatible with flammable refrigerant gases

## Parameters Tables



## Legal Information

The Schneider Electric brand and any trademarks of Schneider Electric SE and its subsidiaries referred to in this guide are the property of Schneider Electric SE or its subsidiaries. All other brands may be trademarks of their respective owners.

This guide and its content are protected under applicable copyright laws and furnished for informational use only. No part of this guide may be reproduced or transmitted in any form or by any means (electronic, mechanical, photocopying, recording, or otherwise), for any purpose, without the prior written permission of Schneider Electric.

Schneider Electric does not grant any right or license for commercial use of the guide or its content, except for a non-exclusive and personal license to consult it on an "as is" basis.

Schneider Electric products and equipment should be installed, operated, serviced, and maintained only by qualified personnel.

As standards, specifications, and designs change from time to time, information contained in this guide may be subject to change without notice.

To the extent permitted by applicable law, no responsibility or liability is assumed by Schneider Electric and its subsidiaries for any errors or omissions in the informational content of this material or consequences arising out of or resulting from the use of the information contained herein.

As part of a group of responsible, inclusive companies, we are updating our communications that contain non-inclusive terminology. Until we complete this process, however, our content may still contain standardized industry terms that may be deemed inappropriate by our customers.

© 2021 Schneider Electric. All rights reserved.

## User Parameters IDNext 902 P

Parameter	Description	Range	MU	Custom	Default	AP1	AP2	AP3
<b>SEt</b>	Control setpoint with range between the minimum <b>LSE</b> setpoint and the maximum <b>HSE</b> setpoint. The setpoint value is set in the 'Machine Status' menu.	<b>LSE...HSE</b>	°C/°F		3.0	3.0	0.0	0.0
<b>diF</b>	Compressor relay activation differential; the compressor stops when the setpoint value is reached (as indicated by the control probe) and restarts at a temperature value equal to the setpoint plus the differential value.	0.1...30.0	°C/°F		2.0	2.0	2.0	2.0
<b>LSE</b>	Minimum setpoint value.	-67.0... <b>HSE</b>	°C/°F		-55.0	-55.0	-55.0	-55.0
<b>HSE</b>	Maximum setpoint value.	<b>LSE</b> ...302	°C/°F		140.0	140.0	140.0	140.0
<b>dEt</b>	Defrost timeout. Determines the maximum duration of the defrost	1...250	min		30	30	30	1
<b>dit</b>	Time interval between one defrost and the next	0...250	hours		6	6	6	-
<b>HAL</b>	Maximum temperature alarm. Temperature value (in an absolute or relative value - see <b>Att</b> ) which, when exceeded, will lead to the activation of alarm signaling.	<b>LAL</b> ...302	°C/°F		150.0	150.0	150.0	150.0
<b>LAL</b>	Minimum temperature alarm. Temperature value (in an absolute or relative value - see <b>Att</b> ) which, when not reached, will lead to the activation of alarm signaling.	-67,0... <b>HAL</b>	°C/°F		-50.0	-50.0	-50.0	-50.0
<b>CA1 (!)</b>	Positive or negative temperature value to be added to the value of Pb1.	-30.0...30.0	°C/°F		0.0	0.0	0.0	0.0
<b>PS1</b>	When enabled ( <b>PS1</b> ≠0) this is the access key for the user parameters.	0...250	num		0	0	0	0
<b>tAb</b>	Reserved: read-only parameter.	/	/		/ (not in applications)			

**Note:** the "User" menu parameters also include **PA2**, which allows access to the "Installer" menu.

**Note:** for the full list of parameters, see the section "**Installer parameters**".

## Installer Parameters IDNext 902 P

Parameter	Description	Range	MU	Custom	Default	AP1	AP2	AP3
<b>SEt</b>	Control setpoint with range between the minimum <b>LSE</b> setpoint and the maximum <b>HSE</b> setpoint. The setpoint value is set in the 'Machine Status' menu.	<b>LSE</b> ... <b>HSE</b>	°C/°F		3.0	3.0	0.0	0.0
<b>CP (Compressor)</b>								
<b>diF</b>	Compressor relay activation differential; the compressor stops when the setpoint value is reached (as indicated by the control probe) and restarts at a temperature value equal to the setpoint plus the differential value.	0.1...30.0	°C/°F		2.0	2.0	2.0	2.0
<b>LSE</b>	Minimum setpoint value.	-67.0... <b>HSE</b>	°C/°F		-55.0	-55.0	-55.0	-55.0
<b>HSE</b>	Maximum setpoint value.	<b>LSE</b> ...302	°C/°F		140.0	140.0	140.0	140.0
<b>HC</b>	The regulator implements either cold operation (set " <b>C</b> (0)") or for hot (set " <b>H</b> (1)").	C/H	flag		C	C	C	H
<b>ont</b>	Regulator power-on time for a inoperable probe: <ul style="list-style-type: none"> <li>if <b>Ont</b> = 1 and <b>Oft</b> = 0 compressor is always on</li> <li>if <b>Ont</b> = 1 and <b>Oft</b> &gt; 0 compressor in duty cycle mode</li> </ul>	0...250	min		15	15	15	15
<b>oFt</b>	Regulator power-off time for a inoperable probe: <ul style="list-style-type: none"> <li>if <b>Oft</b> = 1 and <b>Ont</b> = 0 compressor is always off</li> <li>if <b>Oft</b> = 1 and <b>Ont</b> &gt; 0 compressor in duty cycle mode</li> </ul>	0...250	min		15	15	15	15
<b>don</b>	Compressor relay activation delay time after request	0...250	s		0	0	0	0
<b>doF</b>	Delay time after power-off: the delay time indicated must elapse between deactivation of the compressor relay and the next power-on.	0...250	min		0	0	0	0
<b>dbi</b>	Delay time between power-ons; the delay time indicated must elapse between two consecutive compressor power-ons.	0...250	min		0	0	0	0
<b>Cit</b>	Minimum compressor activation time before it can be deactivated. If <b>Cit</b> = 0 it is not active.	0...250	min		0	0	0	0
<b>CAt</b>	Maximum compressor activation time before it can be deactivated. If <b>CAt</b> = 0 it is not active.	0...250	min		0	0	0	0

Parameter	Description	Range	MU	Custom	Default	AP1	AP2	AP3
odo (!)	Delay in activating outputs after the controller is powered on or after a power failure. <b>0</b> = not active.	0...250	min		0	0	0	0
dcS	"Deep Cooling Cycle" setpoint	-67.0...302	°C/°F		0.0	0.0	0.0	0.0
tdC	"Deep Cooling Cycle" duration	0...250	min		0	0	0	0
dcc	Defrost activation delay after a "Deep Cooling Cycle"	0...250	min		0	0	0	0
<b>dEF (Defrost)</b>								
doH	Defrost cycle activation delay from the call	0...250	min		0	0	0	0
dEt	Defrost timeout. Determines the maximum duration of the defrost	1...250	min		30	30	30	1
dPo	Defrost activation request at power-on, if the temperature measured by Pb2 allows. <ul style="list-style-type: none"> <li>n(0) = no</li> <li>y(1) = yes.</li> </ul>	n/y	flag		n	n	n	n
tCd	Minimum period of time with the compressor ON or OFF before defrost is activated.	-127...127	min		0	0	0	0
Cod	Time with the compressor OFF before defrost is activated	0...250	min		0	0	0	0
dMr	Enables the defrost count reset in the case of manual defrosting. <ul style="list-style-type: none"> <li>n = count reset does not take place</li> <li>y = count reset takes place</li> </ul>	n/y	flag		n	n	n	n
d00	Compressor running time before defrost is activated	0...250	hours		0	0	0	-
d01	<b>d00</b> unit of measure. <ul style="list-style-type: none"> <li>0 = hours</li> <li>1 = minutes</li> <li>2 = seconds.</li> </ul>	0/1/2	num		0	0	0	-
dit	Time interval between one defrost and the next	0...250	hours		6	6	6	0
d11	<b>dit</b> unit of measure. <ul style="list-style-type: none"> <li>0 = hours</li> <li>1 = minutes</li> <li>2 = seconds.</li> </ul>	0/1/2	num		0	0	0	-
d20	Can be used to activate the defrost when the compressor is off. <ul style="list-style-type: none"> <li>0 = disabled. Defrost is not activated.</li> <li>1 = enabled. Defrost is activated when the compressor is off.</li> </ul>	0/1	flag		0	0	0	-
<b>AL (Alarms)</b>								

Parameter	Description	Range	MU	Custom	Default	AP1	AP2	AP3
<b>Att</b>	Sets the absolute or relative value for parameters <b>HAL</b> and <b>LAL</b> . <ul style="list-style-type: none"> <li>• <b>0</b> = absolute value</li> <li>• <b>1</b> = relative value</li> </ul>	0/1	flag		0	0	0	0
<b>AFd</b>	Alarm differential.	0,1...25,0	°C/°F		2.0	2.0	2.0	2.0
<b>HAL</b>	Maximum temperature alarm. Temperature value (in an absolute or relative value - see <b>Att</b> ) which, when exceeded, will lead to the activation of alarm signaling.	<b>LAL</b> ...302	°C/°F		150.0	150.0	150.0	150.0
<b>LAL</b>	Minimum temperature alarm. Temperature value (in an absolute or relative value - see <b>Att</b> ) which, when not reached, will lead to the activation of alarm signaling.	-67,0... <b>HAL</b>	°C/°F		-50.0	-50.0	-50.0	-50.0
<b>PAo</b>	Alarm exclusion time when switching on the controller, after a power failure.	0...10	min*10		0	0	0	0
<b>dAo</b>	Temperature alarm exclusion time after defrosting.	0...999	min		0	0	0	0
<b>oAo</b>	Alarm signaling delay after deactivation of the digital input (door closure). Alarm refers to high and low temperature alarms.	0...10	hours		0	0	0	0
<b>tDo</b>	Door open alarm activation delay time.	0...250	min		0	0	0	0
<b>tAo</b>	Temperature alarm signaling delay time.	0...250	min		0	0	0	0
<b>dAt</b>	Defrost ended due to timeout alarm indication. <ul style="list-style-type: none"> <li>• <b>n(0)</b> = alarm not activated</li> <li>• <b>y(1)</b> = alarm activated.</li> </ul>	n/y	flag		n	n	n	-
<b>EAL</b>	An external alarm inhibits the regulators. <ul style="list-style-type: none"> <li>• <b>0</b> = does not inhibit the regulators</li> <li>• <b>1</b> = compressor and defrost inhibited</li> <li>• <b>2</b> = fans, compressor and defrost inhibited;</li> </ul>	0/1/2	flag		0	0	0	0
<b>SA3</b>	Probe 3 alarm setpoint.	-67,0...302	°C/°F		0.0	0.0	0.0	0.0
<b>dA3</b>	Probe 3 alarm differential.	0.1...30.0	°C/°F		1.0	1.0	1.0	1.0
<b>rFt</b>	Low refrigerant alarm signaling delay.	0...250	min		0 (non nelle applicazioni)			
<b>Lit (Lights and digital inputs)</b>								
<b>dOd</b>	Digital input shuts off utilities. <ul style="list-style-type: none"> <li>• <b>0</b> = disabled</li> <li>• <b>1</b> = disables fans</li> <li>• <b>2</b> = disables compressor</li> <li>• <b>3</b> = disables fans and compressor.</li> </ul>	0...3	num		0	0	0	-

Parameter	Description	Range	MU	Custom	Default	AP1	AP2	AP3
<b>dAd</b>	Digital input activation delay	0...250	min		0	0	0	-
<b>dCo</b>	Compressor switch-off delay from door opening.	0...250	min		1	1	1	-
<b>PrE (Pressure switch)</b>								
<b>PEn</b>	Number of errors permitted per minimum/maximum pressure switch input	0...15	num		0	0	0	-
<b>PEi</b>	Minimum/maximum pressure switch error count interval	1...99	min		1	1	1	-
<b>PEt</b>	Compressor activation delay after pressure switch deactivation	0...255	min		0	0	0	-
<b>EnS (Energy Saving)</b>								
<b>oSP</b>	Temperature value to be added to the setpoint in the case of an enabled reduced set (Economy function).	-30.0...30.0	°C/°F		0.0	0.0	0.0	0.0
<b>odF</b>	Differential offset during an energy saving cycle or reduced set.	0.1...30.0	°C/°F		2.0	2.0	2.0	2.0
<b>Add (Communication)</b>								
<b>Adr</b>	Modbus protocol controller address.	1...247	num		1 (not in applications)			
<b>bAU</b>	Modbus Baudrate selection. <ul style="list-style-type: none"> <li>• <b>96</b> (0) = 9600 baud</li> <li>• <b>192</b> (1) = 19200 baud</li> <li>• <b>384</b> (2) = 38400 baud</li> </ul>	96/192/384	num		96 (not in applications)			
<b>Pty</b>	Modbus parity bit. <ul style="list-style-type: none"> <li>• <b>n</b>(0) = none</li> <li>• <b>E</b>(1) = even</li> <li>• <b>o</b>(2) = odd.</li> </ul>	n/E/o	num		E (not in applications)			
<b>diS (Display)</b>								
<b>dro</b>	Selects the unit of measure used when displaying the temperature read by the probes. ( <b>0</b> = °C, <b>1</b> = °F). <b>Note:</b> changing from °C to °F or vice-versa does NOT change the <b>SEt</b> , <b>diF</b> values, etc. (example: <b>SEt</b> = 10°C becomes 10°F).	0/1	flag		0	0	0	0
<b>CA1 (!)</b>	Positive or negative temperature value to be added to the value of Pb1.	-30.0...30.0	°C/°F		0.0	0.0	0.0	0.0
<b>CA3 (!)</b>	Positive or negative temperature value to be added to the value of Pb3.	-30.0...30.0	°C/°F		0.0	0.0	0.0	0.0

Parameter	Description	Range	MU	Custom	Default	AP1	AP2	AP3
<b>CAi</b>	<p>Activation of the calibration value.</p> <ul style="list-style-type: none"> <li>• <b>0</b> = Adds the value to the temperature value displayed</li> <li>• <b>1</b> = Adds the value to the temperature used by the regulators and not to the one displayed</li> <li>• <b>2</b> = Adds the value to the temperature used by the regulators and to the temperature displayed.</li> </ul>	0/1/2	num		2	2	2	2
<b>LoC</b>	<p>Keypad lock.</p> <ul style="list-style-type: none"> <li>• <b>n(0)</b> = Keypad lock disabled</li> <li>• <b>y(1)</b> = Keypad lock enabled (on startup or when 30 seconds have passed since the last action carried out on the user interface)</li> </ul>	n/y	flag		y	y	y	y
<b>ddd</b>	<p>Selects the type of value to show on the display.</p> <ul style="list-style-type: none"> <li>• <b>0</b> = setpoint</li> <li>• <b>1</b> = Pb1 probe</li> <li>• <b>2</b> = Pb2 probe</li> <li>• <b>3</b> = Pb3 probe.</li> </ul>	0...3	num		1	1	1	1
<b>ddL</b>	<p>Display mode during defrosting.</p> <ul style="list-style-type: none"> <li>• <b>0</b> = display the temperature read by Pb1</li> <li>• <b>1</b> = inhibits reading on the value of Pb1 at the start of defrost and until the setpoint is reached</li> <li>• <b>2</b> = displays label <b>dEF</b> during defrost until the setpoint is reached.</li> </ul>	0/1/2	num		0	0	0	0
<b>Ldd</b>	<p>Display unlock timeout value - label <b>dEF</b></p>	0...250	min		30	30	30	30
<b>ndt</b>	<p>Display with decimal point.</p> <ul style="list-style-type: none"> <li>• <b>n(0)</b> = no</li> <li>• <b>y(1)</b> = yes.</li> </ul>	n/y	flag		y	y	y	y
<b>FSE</b>	<p>Sets the value (COEFF) used by the low-pass filter to calculate the temperature value to be displayed.</p> <ul style="list-style-type: none"> <li>• <b>0</b> = disabled</li> <li>• <b>1</b> = 200</li> <li>• <b>2</b> = 100</li> <li>• <b>3</b> = 50</li> <li>• <b>4</b> = 25</li> <li>• <b>5</b> = 12</li> <li>• <b>6</b> = 6</li> <li>• <b>7</b> = 3.</li> </ul>	0...7	num		0	0	0	0
<b>FdS</b>	<p>Filter disabling threshold.</p>	-67.0...302	°C/°F		0.0	0.0	0.0	0.0
<b>Ftt</b>	<p>Time that has passed beyond the value of <b>FdS</b> before the filter is disabled.</p>	0...250	min		0	0	0	0



Parameter	Description	Range	MU	Custom	Default	AP1	AP2	AP3
<b>FHt</b>	Filter sampling interval.	1...250	s		1	1	1	1
<b>PS1</b>	When enabled ( <b>PS1</b> ≠0) this is the access key for the user parameters.	0...250	num		0	0	0	0
<b>PS2</b>	When enabled ( <b>PS2</b> ≠0) this is the access key for the installer parameters.	0...250	num		15	15	15	15
<b>CnF (Configuration)</b>								
<b>H00</b>	Selects the probe type. <ul style="list-style-type: none"> <li>• <b>0</b> = PTC</li> <li>• <b>1</b> = NTC</li> <li>• <b>2</b> = Pt1000.</li> </ul>	0/1/2	flag		1	1	1	1
<b>H08</b>	Stand-by operating mode. <ul style="list-style-type: none"> <li>• <b>0</b> = display off; the regulators are active and the device signals possible alarms by reactivating the display</li> <li>• <b>1</b> = display off; the regulators and the alarms are blocked</li> <li>• <b>2</b> = the display shows the label "OFF"; the regulators and alarms are inhibited.</li> </ul>	0/1/2	num		2	2	2	2
<b>H11</b>	Configurazione ingresso digitale 1 ( <b>DI</b> ) / polarità. <ul style="list-style-type: none"> <li>• <b>0</b> = disabilitato</li> <li>• <b>±1</b> = sbrinamento</li> <li>• <b>±2</b> = set ridotto</li> <li>• <b>±3</b> = ausiliario</li> <li>• <b>±4</b> = micro-porta</li> <li>• <b>±5</b> = allarme esterno</li> <li>• <b>±6</b> = stand-by</li> <li>• <b>±7</b> = pressostato</li> <li>• <b>±8</b> = abbattimento rapido</li> <li>• <b>±9</b> = luce</li> <li>• <b>±10</b> = risparmio energetico</li> </ul> <p><b>Nota:</b></p> <ul style="list-style-type: none"> <li>• segno "+" indica che l'ingresso è attivo se il contatto è chiuso.</li> <li>• segno "-" indica che l'ingresso è attivo se il contatto è aperto.</li> </ul>	-10...+10	num		0	0	0	0
<b>H21</b>	Configuration of digital output 1 ( <b>Out1</b> ). <ul style="list-style-type: none"> <li>• <b>0</b> = disabled</li> <li>• <b>1</b> = compressor</li> <li>• <b>2</b> = defrost</li> <li>• <b>3</b> = evaporator fans</li> <li>• <b>4</b> = alarm</li> <li>• <b>5</b> = auxiliary</li> <li>• <b>6</b> = stand-by</li> <li>• <b>7</b> = light</li> <li>• <b>8</b> = reserved</li> <li>• <b>9</b> = compressor 2</li> <li>• <b>10</b> = reserved</li> <li>• <b>11</b> = condenser fans</li> <li>• <b>12</b> = heater deadband control</li> <li>• <b>13</b> = reserved</li> </ul>	0...13	num		1	1	1	1

Parameter	Description	Range	MU	Custom	Default	AP1	AP2	AP3
<b>H31</b>	Configuration of $\Delta$ key. <ul style="list-style-type: none"> <li>• 0 = disabled</li> <li>• 1 = defrost</li> <li>• 2 = auxiliary</li> <li>• 3 = reduced set</li> <li>• 4 = stand-by</li> <li>• 5 = reserved</li> <li>• 6 = reserved</li> <li>• 7 = deep cooling</li> <li>• 8 = light.</li> </ul>	0...8	num		1	1	1	0
<b>H32</b>	Configuration of $\nabla$ key. Same as <b>H31</b> .	0...8	num		0	0	0	0
<b>H33</b>	Configuration of $\ominus$ key. Same as <b>H31</b> .	0...8	num		4	4	4	4
<b>H43</b>	Probe Pb3 present. <ul style="list-style-type: none"> <li>• n(0) = not present</li> <li>• y(1) = present</li> <li>• 2EP(2) = second evaporator.</li> </ul>	n/y/2EP	flag		n	n	n	n
<b>H60</b>	Display selected application. 0 = disabled; 1 = AP1; 2 = AP2; 3 = AP3.	0...3	num		1 (not in applications)			
<b>tAb</b>	Reserved: read-only parameter.	/	/		/ (not in applications)			
<b>FPr (UNICARD)</b>								
<b>UL</b>	Transfer of the programming parameters from the controller to the UNICARD.	/	/		- (not in applications)			
<b>Fr</b>	UNICARD formatting. Deletes all data on the UNICARD. <b>Note:</b> the use of parameter <b>Fr</b> results in the loss of all data entered. This operation cannot be reversed.	/	/		- (not in applications)			
<b>FnC (Functions)</b>								
<b>tAL</b>	Force alarm acknowledgment	/	/		- (not in applications)			
<b>rAP</b>	Reset pressure switch alarms	/	/		- (not in applications)			
<b>Cnt</b>	Reset TelevisAir diagnostic counters (see Reset TelevisAir diagnostic counters)	/	/		- (not in applications)			

**Note:** if one or more parameters in folder **CnF** or marked with (!) are changed, the controller must be switched off and then on again to make sure it works properly.

